

Bimonthly Solicitation Questions and Responses Report

Bimonthly Solicitation Title: October 2020

Bimonthly Solicitation Month & Year: October 2020

Projects

| Solicitation ID | Project ID | Project Description |
|-----------------|------------|---|
| SE-01 | 3170-12-00 | Resurfacing project from Geneva National to Forest along STH 50 in Walworth County. |
| SE-01 | 3170-12-00 | Resurfacing project from Geneva National to Forest along STH 50 in Walworth County. |
| SE-01 | 3170-12-00 | Resurfacing project from Geneva National to Forest along STH 50 in Walworth County. |

Questions and Responses

Q1: Has it been determined whether the box culverts will be repaired vs replaced?

R1: Repair. C-64-0087: new bottom. C-64-0086: headwall repair.

Q2: What services will WisDOT provide on the project with regards to hydraulic analysis and/or structure design?

R2: Oversight and review.

Q3: Will the structure survey reports and structure design for the culvert replacements be performed by the consultant or WisDOT?

R3: Consultant

Projects

| Solicitation ID | Project ID | Project Description |
|-----------------|------------|--|
| SE-02 | 3190-11-00 | This project extends from STH 120 to STH 11 and is a mill and resurfacing project, on a rural 2 lane highway, 2-12-foot lanes in each direction for approximately 6 miles. This project will include replacing the bridge over ORE Creek (B-64-665), asphaltic base patching, review of the existing beam guard and drainage culverts for possible upgrades and upgrading about a dozen curb ramps. Some of the curb ramps will require real estate so a real estate plat will also be needed. Other tasks include but are not limited to: project survey, and coordination for Public Involvement, TMP, Section 106, DNR, utilities and the bridge design with BOS. |
| SE-02 | 3190-11-00 | This project extends from STH 120 to STH 11 and is a mill and resurfacing project, on a rural 2 lane highway, 2-12-foot lanes in each direction for approximately 6 miles. This project will include replacing the bridge over ORE Creek (B-64-665), asphaltic base patching, review of the existing beam guard and drainage culverts for possible upgrades and upgrading about a dozen curb ramps. Some of the curb ramps will require real estate so a real estate plat will also be needed. Other tasks include but are not limited to: project survey, and coordination for Public Involvement, TMP, Section 106, DNR, utilities and the bridge design with BOS. |

Bimonthly Solicitation Questions and Responses Report

Questions and Responses

Q1: Will the design consultant be required to develop the right-of-way plat?

R1: Yes

Q2: Who will provide hydraulic analysis and/or structure design?

R2: Consultant - both.

Projects

| Solicitation ID | Project ID | Project Description |
|-----------------|------------|--|
| SE-03 | 1320-25-80 | Reconstruct surrounding roadways for the Foxconn Development in Racine County. |

Questions and Responses

Q1: What level of staff experience is preferred?

R1: Senior level engineer with extensive design and construction experience.

Projects

| Solicitation ID | Project ID | Project Description |
|-----------------|------------|---|
| SE-04 | 2030-10-01 | This solicitation is for full-service design contract on an accelerated schedule. The primary work on this project is the replacement of the two bridges over the Menomonee River. Additional work includes minor rehab on two other structures, replacement of non-compliant curb ramps, resurfacing of the road way, and inspection of and repair of drainage structures as needed. |

Questions and Responses

Q1: Will the bridge design and plans be completed by the consultant?

R1: Yes

Projects

| Solicitation ID | Project ID | Project Description |
|-----------------|------------|--|
| SE-06 | 4060-00-05 | Resurfacing project from IH 41 to USH 45 along STH 28 in Dodge County. |
| SE-06 | 4060-00-05 | Resurfacing project from IH 41 to USH 45 along STH 28 in Dodge County. |

Bimonthly Solicitation Questions and Responses Report

Questions and Responses

Q1: Will curb ramp design be included for intersections at the east end of the project?

R1: Not anticipated at the 3 at the intersection of USH 45 and STH 28. Anticipated at Edgewood Rd and STH 28.

Q2: Are R/W plat services anticipated on this project?

R2: No

Projects

| Solicitation ID | Project ID | Project Description |
|-----------------|------------|--|
| SW-01 | 1370-00-05 | Treat the pavement with a mill and overlay.Update curb ramps as needed to meet ADA requirements.Investigate the need for real estate acquisition at curb ramps.End the project at the beginning of 1370-00-73. |
| SW-01 | 1370-00-05 | Treat the pavement with a mill and overlay.Update curb ramps as needed to meet ADA requirements.Investigate the need for real estate acquisition at curb ramps.End the project at the beginning of 1370-00-73. |
| SW-01 | 1370-00-05 | Treat the pavement with a mill and overlay.Update curb ramps as needed to meet ADA requirements.Investigate the need for real estate acquisition at curb ramps.End the project at the beginning of 1370-00-73. |
| SW-01 | 1370-00-05 | Treat the pavement with a mill and overlay.Update curb ramps as needed to meet ADA requirements.Investigate the need for real estate acquisition at curb ramps.End the project at the beginning of 1370-00-73. |
| SW-01 | 1370-00-05 | Treat the pavement with a mill and overlay.Update curb ramps as needed to meet ADA requirements.Investigate the need for real estate acquisition at curb ramps.End the project at the beginning of 1370-00-73. |
| SW-01 | 1370-00-05 | Treat the pavement with a mill and overlay.Update curb ramps as needed to meet ADA requirements.Investigate the need for real estate acquisition at curb ramps.End the project at the beginning of 1370-00-73. |
| SW-01 | 1370-00-05 | Treat the pavement with a mill and overlay.Update curb ramps as needed to meet ADA requirements.Investigate the need for real estate acquisition at curb ramps.End the project at the beginning of 1370-00-73. |
| SW-01 | 1370-00-05 | Treat the pavement with a mill and overlay.Update curb ramps as needed to meet ADA requirements.Investigate the need for real estate acquisition at curb ramps.End the project at the beginning of 1370-00-73. |
| SW-01 | 1370-00-05 | Treat the pavement with a mill and overlay.Update curb ramps as needed to meet ADA requirements.Investigate the need for real estate acquisition at curb ramps.End the project at the beginning of 1370-00-73. |
| SW-01 | 1370-00-05 | Treat the pavement with a mill and overlay.Update curb ramps as needed to meet ADA requirements.Investigate the need for real estate acquisition at curb ramps.End the project at the beginning of 1370-00-73. |

Questions and Responses

Q1: Is grading work expected?

R1: No

Q2: Is the 0.75-mile concrete pavement on the east end of the project limits included as part of the project?

R2: Yes, minor patching.

Bimonthly Solicitation Questions and Responses Report

Q3: Will design coordination be required for project 1370-00-73?

R3: No

Q4: Is there any bridge rehabilitation work included in the project?

R4: No

Q5: Is railroad coordination expected?

R5: No

Q6: Will guardrail be upgraded to MGS?

R6: No

Q7: Is a plat anticipated, or is right of way acquisition anticipated to be handled with a PLE/TLE exhibit?

R7: TBD

Q8: Is it anticipated the project will be on the screening list for arch or history?

R8: TBD

Q9: Can you clarify the base and advanced date for the PS&E and LET?

R9: Base date: PS&E: 8/1/2027; LET: 12/14/2027
Advanced date: PS&E: 5/1/2024; LET: 8/13/2024

Projects

Bimonthly Solicitation Questions and Responses Report

| Solicitation ID | Project ID | Project Description |
|-----------------|------------|--|
| SW-02 | 3060-03-00 | Treat the pavement with a 4-inch mill and overlay.No structure work included in the project. |
| SW-02 | 3060-03-00 | Treat the pavement with a 4-inch mill and overlay.No structure work included in the project. |
| SW-02 | 3060-03-00 | Treat the pavement with a 4-inch mill and overlay.No structure work included in the project. |

Questions and Responses

Q1: Will Curb ramps and spot curb & gutter be included in the design?

R1: No, Canal Rd and Converse Ave are outside of the project limits.

Q2: Are intersection improvements part of the project?

R2: No

Q3: Are additional survey needs anticipated?

R3: TBD; DTM is from a flight.